




NOTE: CLEAN BOTH CONNECTING SURFACES OF TERMINAL PADS AND TERMINAL FLANGE WITH SAND PAPER AND COAT SUPPLIED COMPOUND BEFORE CONNECTING.



DETAIL OF UPPER AND LOWER TERMINAL PADS



ANCHOR BOLT DETAIL



DIMENSIONS IN INCHES (APPROX.)

A STRUCTURE HEIGHT	B LOWER TERM. PAD HEIGHT	C UPPER TERM. PAD HEIGHT	WEIGHT (PER 3 PHASE)
96 [2438]	168 1/4 [4274]	222 7/16 [5650]	5759 lbs. [2612 kg.]
120 [3048]	192 1/4 [4883]	246 7/16 [6260]	5905 lbs. [2678 kg.]
144 [3658]	216 1/4 [5493]	270 7/16 [6868]	6029 lbs. [2734 kg.]

TERMINAL PAD LOADING

DIRECTION OF LOAD	LOADING, LBS	LOADING, KG
IN-LINE WITH TERMINAL PADS	281	127
PERPENDICULAR TO TERMINAL PADS	108	76
VERTICAL TO TERMINAL PADS	225	102

PROPOSAL DRAWING
NOT FOR CONSTRUCTION
SPECIFICATIONS SUBJECT
TO CHANGE

THIS DRAWING AND THE INFORMATION HEREIN ARE THE PROPERTY OF SOUTHERN STATES, LLC AND ARE PROVIDED FOR THE EXCLUSIVE USE OF OUR CUSTOMERS, SUPPLIERS AND LICENSEES. THE DRAWING OR INFORMATION IS NOT TO BE REPRODUCED OR COPIED BY ANY OTHER PARTY WITHOUT THE SPECIFIC WRITTEN APPROVAL OF SOUTHERN STATES, LLC.

Southern States, LLC
2000 W. 10TH AVENUE
DENVER, CO 80202
TEL: (303) 441-3100

PROPOSAL OUTLINE
CSV 121-145 KV
84" PHASE SPACING
(40 KA, -40C)

DATE	BY	APP. BY	REVISION
7/21/06	CMB		

PROJECT NO. 1 OF SHEET NO. PD-CSV 121-145 KV_84